

Fixture Location/Description	Fixture ID #	Initial Test Date	Initial Test Result
Southeast Boy's Restroom, South	20820400-008BF25A	11/20/2024	5.37
Southeast Boy's Restroom, North	20820400-009BF25A	11/20/2024	5.35
Southeast Girl's Restroom, North	20820400-012BF25A	11/20/2024	3.72
Classroom 4 Faucet	20820400-014CF25A	11/20/2024	7.57
Classroom 4 Drinking Fountain	20820400-053DW25A	11/20/2024	7.34
IMC	20820400-010SF25A	11/20/2024	10.7
Classroom 5 Faucet	20820400-015CF25A	11/20/2024	8.54
Classroom 5 Drinking Fountain	20820400-054DW25A	11/20/2024	7.27
Staff Restroom Across from Classroom 5	20820400-062BF25A	11/20/2024	3.75
Classroom 6 Faucet	20820400-019CF25A	11/20/2024	9.18
Classroom 6 Drinking Fountain	20820400-055DW25A	11/20/2024	5.22
Central Boy's Restroom, South	20820400-016BF25A	11/20/2024	1.33
Central Boy's Restroom, North	20820400-017BF25A	11/20/2024	2.06
Central Girl's Restroom, South	20820400-020BF25A	11/20/2024	5.4
Central Girl's Restroom, North	20820400-021BF25A	11/20/2024	2.29
Center East Hallway Drinking Fountain	20820400-018DW25A	11/20/2024	ND
Center East Hallway Water Bottle Filler	20820400-063WB25A	11/20/2024	ND
Classroom 7 Faucet	20820400-022CF25A	11/20/2024	14
Classroom 7 Drinking Fountain	20820400-056DW25A	11/20/2024	3.82
Classroom 8 Faucet	20820400-025CF25A	11/20/2024	10.5
Classroom 8 Drinking Fountain	20820400-057DW25A	11/20/2024	1.05
Classroom 9	20820400-027CF25A	11/20/2024	3.74
Library Faucet	20820400-039CF25A	11/20/2024	2.99
Library Drinking Fountain	20820400-060DW25A	11/20/2024	4.59
Office Restroom	20820400-037BF25A	11/20/2024	3.34
Office Breakroom	20820400-038NS25A	11/20/2024	9.68
Northwest Hallway	20820400-042DW25A	11/20/2024	ND
Northwest Boy's Restroom	20820400-040BF25A	11/20/2024	2.57
Northwest Girl's Restroom	20820400-044BF25A	11/20/2024	3.01
Classroom 10 Faucet	20820400-046CF25A	11/20/2024	4.26
Classroom 10 Drinking Fountain	20820400-058DW25A	11/20/2024	0.487
Classroom 11 Faucet	20820400-048CF25A	11/20/2024	19.3
Classroom 11 Drinking Fountain	20820400-059DW25A	11/20/2024	0.657
Gym Restroom Hall, South	20820400-034DW25A	11/20/2024	5.48
Gym Restroom Hall, North	20820400-067DW25A	11/20/2024	3.32
Gym Girl's Restroom	20820400-032BF25A	11/20/2024	4.11
Gym Boy's Restroom	20820400-033BF25A	11/20/2024	23.6
Classroom 3 Faucet	20820400-013CF25A	11/20/2024	5.64
Classroom 3 Drinking Fountain	20820400-052DW25A	11/20/2024	0.813
Classroom 2 Faucet	20820400-007CF25A	11/20/2024	4.97
Classroom 2 Drinking Fountain	20820400-051DW25A	11/20/2024	3.12
Classroom 1 Faucet	20820400-006CF25A	11/20/2024	10.9
Classroom 1 Drinking Fountain	20820400-050DW25A	11/20/2024	4.26
Cafeteria Water Bottle Filler	20820400-065WB25A	11/20/2024	ND
Cafeteria Drining Fountain	20820400-064DW25A	11/20/2024	ND
Kitchen Faucet	20820400-003KF25A	11/20/2024	4.5
Kitchen Handwash Sink	20820400-001KF25A	11/20/2024	6.55